



**SUPERIOR**  
RADIANT PRODUCTS

## Superior Radiant Series 750 LA Series Specification

Acceptable Manufacturer: Superior Radiant Products.

---

- Canadian Location:  
563 Barton St.  
Stoney Creek, ON, Canada L8E 5S1
  - United States Location:  
980 Cobb Place Blvd. NW Unit 100  
Kennesaw, GA 30144
- 

Contact: Toll Free: 1 (800) 527-4328  
Phone: 1 (905) 664-8274 - Fax: (905) 664-8846  
Email: [sales@superiorradiant.com](mailto:sales@superiorradiant.com)  
Web: <http://www.superiorradiant.com>.

Low Intensity, Low Clearance, Low temperature, Even Heat Single Stage Infrared Tube Heaters. Heavy duty industrial/commercial infrared heater featuring the best overall performance in the industry. Firing rates as called for in the Contract documents, either 60 MBH or 100 MBH. Designed for low clearance, even heat applications in specialty fueled vehicle or similar facilities that must comply with NFPA 30A 7.6.6, requiring maximum heater surface temperature of 750° F. All Series 750 units include our patented design, which provides unequalled even heat distribution with end to end output variance of less than 15%. Baffles required as per manufacturer's instructions. Assemblies shall be CSA approved low intensity heater to latest ANSI Z83.20 and CSA 2.34 for use in commercial and industrial applications and shall also be CSA tested and certified to comply with NFPA 30A 7.6.6. Burner shall be a positive pressure burner system where exhaust gases and other products of combustion are not routed through the blower. The burner shall operate at a minimum gas inlet pressure of 5.0 inches W.C. (natural gas) and draw no more than 1 Amp at 120VAC, 60Hz.

Burner head shall be chrome plated steel and burner controls shall be located outside of the air supply stream to allow service and diagnostic control checks with the burner operating. Reflector shall have a minimum 10-sided reflector design reflecting virtually 100% of the infrared energy out and away from the emitter tubes. Reflector shall be "Deep Dish" design with emitter tubes fully recessed within reflector. Reflectors with fewer than 10 surfaces will not be allowed as they allow energy to bounce back to the main heat exchanger tubing. Reflector shall be mill-finished aluminum, ASTM 1100, .024 inch thickness aluminum sheet metal with two reflector support brackets for each 10 feet (3048 mm) reflector section. Reflectors shall extend below the lowest position of the tubing at all times. Reflector end caps shall be fitted to the end of each reflector run to reduce convective heat loss, and shall be standard equipment. Emitter Tube shall be 4 inch (102 mm) diameter, minimum 16 gauge thickness. Combustion Tube shall be 4 inches (102 mm) diameter, 16 gauge, type 1 aluminized steel tubing and be required for all firing rates. Hot rolled steel combustion tubing shall not be allowed. Combustion tubing shall incorporate a welded, 11 gauge steel, 4 bolt flange to orient the burner to the tube as designed. Couplings shall be 16 gauge aluminized steel, minimum 12 inches in length and be of heavy duty design incorporating two 1-inch wide draw bands.

This product was specified based on best practice design to meet the specific engineered design criteria for this project.

Any submission for substitution must include the following material for consideration, or bid will be deemed unqualified and rejected:

- Independent testing to show maximum 750° F tube temperatures, and even distribution of hot gases along complete length of emitter tube with a maximum variance of 15%
- Professional Engineer Stamped Design, calculations and complete set of stamped drawings with alternate system.
- Stamped fuel usage data showing a minimum 20% fuel savings over specified Superior Radiant Model



- Verification that Manufacturer successfully completed and passed the auditing requirements for ISO 9001 Quality Management System (QMS).

